

TERMINAL LAYOUT

NOTES


- EXTRA TERMINALS MAY BE FITTED. THE NUMBER OF TERMINALS MUST NOT EXCEED THE MAXIMUM SPECIFIED IN THE TERMINAL BOX CERTIFICATE - CONSULT EXPO TECHNOLOGIES.
- ALL TERMINALS MUST BE Ex e CERTIFIED
- MAXIMUM PER TERMINAL AT 55°C: 250V 4A (AC-15)
- TERMINAL BOX : IP66 MATERIAL: STAINLESS STEEL 316
- SWITCHES: NTERMEDIATE LOW PRESSURE CONTACTS AC-IS 4A 250V Ex d IIC T6

APP'D	JPDB	ISSUE:	1		
		MOD. No:	DRAWN		
CHK'D	AW	DATE:	22/10/18		
		APPROVED:	30/11/18		
DR'WN	KDJ	DRAWING STATUS:			

Expo Technologies Limited

TITLE
 NITROGEN BUFFER P AND I DIAGRAM

JOB No: CUSTOMER:



SCALE
 NTS

DRAWING No.

CSP2-440S-000-PI

SHEET No. 1 OF 1